

Unplanned maintenance is never easy, and finding new OEM parts to complete your repairs on short notice can be costly and time consuming. Which is why we recommend maintaining an on-site supply of the most common breaker parts to assist you in getting your breaker back up and running in the shortest amount of time.



WavePro WP-40
Maintenance Manual -- DEH-137
Renewal Parts - DEF 005

Part Number	Description	Qty
Disconnects		
568B450G2	Primary Disconnects (Lower)	6
139C4549G4	Primary Disconnect (Upper)	6
10080736G1	Breaker Secondary Disconnect	1
0228C8408G005	Equipment Secondary Disconnect	1

Contacts		
K9921572G3	Movable Arcing Contact	15
193A1126G9	Movable Intermediate Contact - Left	3
193A1126G7	Movable Intermediate Contact - Right	3
193A1126G10	Movable Main Contact - Left	9
193A1126G8	Movable Main Contact - Right	9
295B408G3	Stationary Arcing Contact	15
193A1127G2	Stationary Intermediate Contact - Left	3
193A1127G1	Stationary Intermediate Contact - Right	3
193A1125G2	Stationary Main Contact - Left	9
193A1125G1	Stationary Main Contact - Right	9

Charging		
10060164G1	Charging Handle	1
568B596G4	48VDC Charging Motor	1
568B596G5	110VAC/125VDC Charging Motor	1
568B596G6	240VAC/250VDC Charging Motor	1
139C4458G1	Cut-off Switch	1

Arc Quenchers		
161D6507G2	Arc Quencher	3

Part Number	Description	Qty
Close		
WPRCLF60120	120VAC/60Hz Remote Close Kit (Close Coil & Circuit Board)	1
10080505G1	120VAC/60Hz Close Solenoid	1
WPRCLFDC125	125VDC Remote Close Kit (Close Coil & Circuit Board)	1
10080505G4	125VDC Close Solenoid	1

Trip		
425D385G92	Flux Shifter	1
GW740L4XXXRXXXX	New Entelliguard Trip Unit (LSIG)	1
GTP4000U4064	4000A Rating Plug	1
10060051P3	Entelliguard Trip Unit Door	1

Accessories		
WPBALF	Bell Alarm Kit	1
10080044G1	Bell Alarm Module	1
139C4378G107	120VAC/60Hz Shunt Trip Coil	1
139C4378G113	240VAC/60Hz Shunt Trip Coil	1
WPS1LFDC125	125VDC Shunt Trip Kit	1
139C4378G104	125VDC Shunt Trip Coil	1
139C4378G105	250VDC Shunt Trip Coil	1
WPUVLFDC125	125VDC Under Voltage Device Kit	1
WPAUXLF7STG	Aux Switch Assembly (7 stage)	1
WPCTRLFKIT1	Operation Counter	1
121C2870G4	Open Fuse Lockout	1

Racking Mech		
10080553G1	Racking Mechanism	1
10080553G3	Racking Mechanism (OEM)	1

New Replacement Circuit Breaker

WE3NNPVF1XAXXXX

WPX-40, 120VAC, E/O, LSI with Shunt Trip, 4 Stage Aux Switch

